



NOTES

1. ALL CONNECTIONS TO EXISTING STRUCTURES WILL BE CORE DRILLED.
2. "KOR-N-SEAL" OR APPROVED EQUIVALENT PRE-CAST GASKETED BOOT CONNECTION WILL BE USED FOR CONNECTING PIPE TO MANHOLE.
3. MANHOLE COVERS WILL BE CAST WITH THE WORDS "SANITARY SEWER".
4. INDIVIDUAL ADJUSTMENT RINGS MAY BE CONCRETE OR HDPE.
5. IF MANHOLE IS IN AN IMPERVIOUS (PAVEMENT/CONCRETE) AREA, VENT MAY BE EXTENDED TO ADJACENT BOULEVARD AREA.



CITY OF BURNSVILLE - ENGINEERING DEPT.
SANITARY SEWER FORCEMAIN
AIR RELEASE MANHOLE

Plate No.	SS-7
Revision Date	02/2021
File Location: S:\Details/english/Sanitary Sewer/SS07-Air Release MH.dwg	